



M.J. Reider Associates, Inc.

ENVIRONMENTAL TESTING LABORATORY
U.S. EPA/PA DEP #06-00003

Certificate of Analysis

Laboratory No.: 2305494

Report: 03/07/23

Lab Contact: Paulina Laudan Webb

Attention: Ken Patterson

Project Info: Misc. testing

Reported To: Muhlenberg Senior High School

801 Bellevue Avenue, c/o Muhlenberg School District
Laureldale, PA 19605

Lab ID: 2305494-01

Collected By: Client

Sampled: 03/03/23 13:47

Received: 03/06/23 12:14

Sample Desc: Kettle Faucet, Kitchen

Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	0.002	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB

Lab ID: 2305494-02

Collected By: Client

Sampled: 03/03/23 14:05

Received: 03/06/23 12:14

Sample Desc: Cooler East Side of Gym

Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB

Lab ID: 2305494-03

Collected By: Client

Sampled: 03/03/23 14:17

Received: 03/06/23 12:14

Sample Desc: Cooler H.S. Main Hall @ Office

Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB

Lab ID: 2305494-04

Collected By: Client

Sampled: 03/03/23 14:25

Received: 03/06/23 12:14

Sample Desc: Cooler H.S. 1st Floor South

Sample Type: Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB



107 Angelica Street ○ Reading, PA 19611 ○ www.mjreider.com ○ (610) 374-5129 ○ fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.

NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)

M.J. Reider Associates, Inc.

Lab ID: 2305494-05 **Collected By:** Client **Sampled:** 03/03/23 14:33 **Received:** 03/06/23 12:14
Sample Desc: Cooler H.S. 1st Floor North **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB

Lab ID: 2305494-06 **Collected By:** Client **Sampled:** 03/03/23 00:00 **Received:** 03/06/23 12:14
Sample Desc: Cooler H.S. 2nd Floor South **Sample Type:** Grab
Comments: The cooler is not functioning at this location - no sample was taken

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Field							
No Sample	0			MJRA	03/03/23		NAG

Lab ID: 2305494-07 **Collected By:** Client **Sampled:** 03/03/23 14:59 **Received:** 03/06/23 12:14
Sample Desc: Cooler H.S. B-Wing by Art Rooms **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB

Lab ID: 2305494-08 **Collected By:** Client **Sampled:** 03/03/23 15:05 **Received:** 03/06/23 12:14
Sample Desc: Cooler H.S. B-Wing by Food Labs **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB

Lab ID: 2305494-09 **Collected By:** Client **Sampled:** 03/03/23 15:30 **Received:** 03/06/23 12:14
Sample Desc: Cooler H.S. Main Lobby by Restrooms **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB



107 Angelica Street Reading, PA 19611 www.mjreider.com (610) 374-5129 fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.

NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)

M.J. Reider Associates, Inc.

Lab ID: 2305494-10 **Collected By:** Client **Sampled:** 03/03/23 15:35 **Received:** 03/06/23 12:14
Sample Desc: Cooler H.S. Band Wing **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB

Lab ID: 2305494-11 **Collected By:** Client **Sampled:** 03/03/23 15:48 **Received:** 03/06/23 12:14
Sample Desc: Cooler H.S. Pool Girls Locker Room **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB

Lab ID: 2305494-12 **Collected By:** Client **Sampled:** 03/03/23 15:56 **Received:** 03/06/23 12:14
Sample Desc: Cooler H.S. Pool Boys Locker Room **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB

Lab ID: 2305494-13 **Collected By:** Client **Sampled:** 03/03/23 16:07 **Received:** 03/06/23 12:14
Sample Desc: Cooler H.S. 2nd Floor New Weight Room **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB

Lab ID: 2305494-14 **Collected By:** Client **Sampled:** 03/04/23 11:09 **Received:** 03/06/23 12:14
Sample Desc: Cooler C.E. Cole Cafeteria **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB



107 Angelica Street Reading, PA 19611 www.mjreider.com (610) 374-5129 fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.

NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)

M.J. Reider Associates, Inc.

Lab ID: 2305494-15 **Collected By:** Client **Sampled:** 03/04/23 11:18 **Received:** 03/06/23 12:14
Sample Desc: Cooler C.E. Cole Locker Room 126 **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB

Lab ID: 2305494-16 **Collected By:** Client **Sampled:** 03/04/23 11:23 **Received:** 03/06/23 12:14
Sample Desc: Cooler C.E. Cole Locker Room 125 **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB

Lab ID: 2305494-17 **Collected By:** Client **Sampled:** 03/04/23 11:33 **Received:** 03/06/23 12:14
Sample Desc: Cooler C.E. Cole 1st Floor Classrooms **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB

Lab ID: 2305494-18 **Collected By:** Client **Sampled:** 03/04/23 11:45 **Received:** 03/06/23 12:14
Sample Desc: Cooler C.E. Cole 2nd Floor Classrooms **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB

Lab ID: 2305494-19 **Collected By:** Client **Sampled:** 03/04/23 12:32 **Received:** 03/06/23 12:14
Sample Desc: Kettle MJHS Kitchen **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	0.008	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB



107 Angelica Street Reading, PA 19611 www.mjreider.com (610) 374-5129 fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.

NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)

M.J. Reider Associates, Inc.

Lab ID: 2305494-20 **Collected By:** Client **Sampled:** 03/04/23 12:40 **Received:** 03/06/23 12:14
Sample Desc: Cooler MJHS 2nd Floor C Block **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB

Lab ID: 2305494-21 **Collected By:** Client **Sampled:** 03/04/23 12:49 **Received:** 03/06/23 12:14
Sample Desc: Cooler MJHS 1st Floor C Block **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/06/23		MPB

Lab ID: 2305494-22 **Collected By:** Client **Sampled:** 03/04/23 12:57 **Received:** 03/06/23 12:14
Sample Desc: Cooler MJHS 2nd Floor D Block @ Girls Lav. **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/07/23		MPB

Lab ID: 2305494-23 **Collected By:** Client **Sampled:** 03/04/23 13:02 **Received:** 03/06/23 12:14
Sample Desc: Cooler MJHS 2nd Floor E-Block @ Girls Lav. **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/07/23		MPB

Lab ID: 2305494-24 **Collected By:** Client **Sampled:** 03/04/23 13:10 **Received:** 03/06/23 12:14
Sample Desc: Cooler MJHS 2nd Floor E-Block East **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/07/23		MPB



107 Angelica Street Reading, PA 19611 www.mjreider.com (610) 374-5129 fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.

NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)

M.J. Reider Associates, Inc.

Lab ID: 2305494-25 **Collected By:** Client **Sampled:** 03/04/23 13:17 **Received:** 03/06/23 12:14
Sample Desc: Cooler MJHS 1st Floor E-Block East **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/07/23		MPB

Lab ID: 2305494-26 **Collected By:** Client **Sampled:** 03/04/23 13:25 **Received:** 03/06/23 12:14
Sample Desc: Cooler MJHS 1st Floor E-Block @ Girls Lav. **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/07/23		MPB

Lab ID: 2305494-27 **Collected By:** Client **Sampled:** 03/04/23 13:30 **Received:** 03/06/23 12:14
Sample Desc: Cooler MJHS 1st Floor D-Block @ Girls lav. **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/07/23		MPB

Lab ID: 2305494-28 **Collected By:** Client **Sampled:** 03/04/23 13:40 **Received:** 03/06/23 12:14
Sample Desc: Cooler MJHS Science Wing Hall **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/07/23		MPB

Lab ID: 2305494-29 **Collected By:** Client **Sampled:** 03/04/23 13:50 **Received:** 03/06/23 12:14
Sample Desc: Cooler MJHS Boys Locker Room **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	03/07/23		MPB



107 Angelica Street Reading, PA 19611 www.mjreider.com (610) 374-5129 fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.

NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)

**M.J. Reider Associates, Inc.**107 Angelica St, Reading PA, 19611
610-374-5129 www.mjreider.com

Client Code: 0553

Project Manager: Paulina Laudan Webb

Report To: Muhlenberg Senior High School - Ken Patterson - 801 Bellevue Avenue, c/o Muhlenberg School District, Laureldale, PA 19605

Invoice To: Muhlenberg Senior High School - Ken Patterson - 801 Bellevue Avenue, c/o Muhlenberg School District, Laureldale, PA 19605

**WORK ORDER
Chain of Custody**

2305494



Client: Muhlenberg Senior High School

Project: Misc. testing

Project Notes: Location for bottle drop off: Admin Building: 801 E. Bellevue Avenue, Reading, PA. 19605

Collected By : Marc Wolfe
(Full Name)

Comments: _____

2305494-01 Kettle Faucet, Kitchen
Pb EPA 200.8

Matrix: Drinking Water

Type: Grab

Date/Time: 3/3/2023 1:47pm

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-02 Cooler, East Side of Gym
Pb EPA 200.8

Matrix: Drinking Water

Type: Grab

Date/Time: 3/3/2023 2:05pm

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-03 Cooler, H.S. main hall @ office
Pb EPA 200.8

Matrix: Drinking Water

Type: Grab

Date/Time: 3/3/2023 2:17pm

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-04 Cooler, H.S. 1st Floor South
Pb EPA 200.8

Matrix: Drinking Water

Type: Grab

Date/Time: 3/3/2023 2:25pm

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-05 Cooler, H.S. 1st Floor North
Pb EPA 200.8

Matrix: Drinking Water

Type: Grab

Date/Time: 3/3/2023 2:33pm

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-06 Cooler H.S. 2nd Floor South
Pb EPA 200.8

Matrix: Drinking Water

Type: Grab

Date/Time: Not functioning

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-07 Cooler, H.S. B-wing by Art Rooms
Pb EPA 200.8

Matrix: Drinking Water

Type: Grab

Date/Time: 3/3/2023 2:59pm

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-08 Cooler H.S. B-wing by Food Lakes
Pb EPA 200.8

Matrix: Drinking Water

Type: Grab

Date/Time: 3/3/2023 3:05pm

A - PI 250ml leak-proof (Nalgene) HNO3

Relinquished By

Date/Time

Received By

Date/Time

Relinquished By

Date/Time

Received By

Date/Time

Relinquished By

Date/Time

Received at Laboratory By

Date/Time

The Client, by signing (or having the client's agent sign), agrees to MJRA's Terms and Conditions and to pay for the above requested services including any additional associated fees incurred.

Page 1 of 4

Printed: 2/8/2023 10:45:59AM

Sample Kit Prepared By <u>JSV</u>	Date/Time <u>2/8/23</u>
Sample Temp (°C): <u>18.8</u>	
Samples on Ice?	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> NA <input type="checkbox"/>
Approved By: <u>[Signature]</u>	
Entered By: <u>[Signature]</u>	

Page 7 of 11



M.J. Reider Associates, Inc.

Client Code: 0553

Project Manager: Paulina Laudan Webb

Client: Muhlenberg Senior High School

Project: Misc. testing

2305494

Collected By :

(Full Name)

Marc Wolfe

Comments:

2305494-09
Pb EPA 200.8

Cooler, H.S. main lobby by restrooms

Matrix: Drinking Water

Type: Grab

Date/Time:

3/3/2023 3:30pm

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-10
Pb EPA 200.8

Cooler, H.S. Band wing

Matrix: Drinking Water

Type: Grab

Date/Time:

3/3/2023 3:35pm

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-11
Pb EPA 200.8

Cooler, H.S. Pool Girls Locker Room

Matrix: Drinking Water

Type: Grab

Date/Time:

3/3/2023 3:48pm

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-12
Pb EPA 200.8

Cooler, H.S. Pool Boys Locker Room

Matrix: Drinking Water

Type: Grab

Date/Time:

3/3/2023 3:56pm

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-13
Pb EPA 200.8

Cooler, H.S. 2nd Floor New Weight Room

Matrix: Drinking Water

Type: Grab

Date/Time:

3/3/2023 4:07pm

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-14
Pb EPA 200.8

Cooler, C.E. Cole Cafeteria

Matrix: Drinking Water

Type: Grab

Date/Time:

3/4/2023 11:09 AM

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-15
Pb EPA 200.8

Cooler, C.E. Cole Locker Room 126

Matrix: Drinking Water

Type: Grab

Date/Time:

3/4/2023 11:18 AM

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-16
Pb EPA 200.8

Cooler, C.E. Cole Locker Room 125

Matrix: Drinking Water

Type: Grab

Date/Time:

3/4/2023 11:23 AM

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-17
Pb EPA 200.8

Cooler, C.E. Cole 1st Floor classrooms

Matrix: Drinking Water

Type: Grab

Date/Time:

3/4/2023 11:33

A - PI 250ml leak-proof (Nalgene) HNO3

Relinquished By

Date/Time

Received By

Date/Time

Relinquished By

Date/Time

Received By

Date/Time

Relinquished By

Date/Time

Received at Laboratory By

Date/Time

The Client, by signing (or having the client's agent sign), agrees to MJRA's Terms and Conditions and to pay for the above requested services including any additional associated fees incurred.

Page 2 of 4

Printed: 2/8/2023 10:45:59AM

Sample Kit Prepared By JSV	Date/Time 2/8/23
Sample Temp (°C): 18.8	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> NA <input type="checkbox"/>
Samples on Ice? Approved By: Entered By:	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> NA <input type="checkbox"/> JSV

Page 8 of 11

Report Template: wko WorkOrder COC Is



M.J. Reider Associates, Inc.

Client Code: 0553

Project Manager: Paulina Laudan Webb

Client: Muhlenberg Senior High School

Project: Misc. testing

2305494

Collected By :

(Full Name)

Marc Wolfe

Comments:

2305494-18	Cooler, C.E. Cole 2 nd Floor Pb EPA 200.8 Classrooms	Matrix: Drinking Water	Type: Grab	Date/Time: 3/4/2023 11:45 AM
			A - PI 250ml leak-proof (Nalgene) HNO3	
2305494-19	Kettle, MJHS Kitchen Pb EPA 200.8	Matrix: Drinking Water	Type: Grab	Date/Time: 3/4/2023 12:32 pm
			A - PI 250ml leak-proof (Nalgene) HNO3	
2305494-20	Cooler, MJHS 2 nd Floor C Block Pb EPA 200.8	Matrix: Drinking Water	Type: Grab	Date/Time: 3/4/2023 12:40 pm
			A - PI 250ml leak-proof (Nalgene) HNO3	
2305494-21	Cooler, MJHS 1 st Floor C Block Pb EPA 200.8	Matrix: Drinking Water	Type: Grab	Date/Time: 3/4/2023 12:49 pm
			A - PI 250ml leak-proof (Nalgene) HNO3	
2305494-22	Cooler, MJHS 2 nd Floor D Block Pb EPA 200.8 @ girls Lav.	Matrix: Drinking Water	Type: Grab	Date/Time: 3/4/2023 12:57 pm
			A - PI 250ml leak-proof (Nalgene) HNO3	
2305494-23	Cooler, MJHS 2 nd Floor E-Block Pb EPA 200.8 @ girls lav.	Matrix: Drinking Water	Type: Grab	Date/Time: 3/4/2023 1:02 pm
			A - PI 250ml leak-proof (Nalgene) HNO3	
2305494-24	Cooler, MJHS 2 nd Floor E-Block EAST Pb EPA 200.8	Matrix: Drinking Water	Type: Grab	Date/Time: 3/4/2023 1:10 pm
			A - PI 250ml leak-proof (Nalgene) HNO3	
2305494-25	Cooler, MJHS 1 st Floor E-Block - EAST Pb EPA 200.8	Matrix: Drinking Water	Type: Grab	Date/Time: 3/4/2023 1:17 pm
			A - PI 250ml leak-proof (Nalgene) HNO3	
2305494-26	Cooler, MJHS 1 st Floor E-Block @ Pb EPA 200.8 girls lav.	Matrix: Drinking Water	Type: Grab	Date/Time: 3/4/2023 1:25 pm
			A - PI 250ml leak-proof (Nalgene) HNO3	

Relinquished By

Date/Time

Received By

Date/Time

Relinquished By

Date/Time

Received By

Date/Time

Relinquished By

Date/Time

Received at Laboratory By

Date/Time

The Client, by signing (or having the client's agent sign), agrees to MJRA's Terms and Conditions and to pay for the above requested services including any additional associated fees incurred.

Sample Kit Prepared By	Date/Time
Sample Temp (°C):	18.8
Samples on Ice?	Yes No NA
Approved By:	
Entered By:	



M.J. Reider Associates, Inc.

Client Code: 0553

Project Manager: Paulina Laudan Webb

Client: Muhlenberg Senior High School

Project: Misc. testing

2305494

Collected By : Marc Wolfe
(Full Name)

Comments: _____

2305494-27 Cooler, MJHS, 1st Floor D-Block @ girls lav.
Pb EPA 200.8

Matrix: Drinking Water

Type: Grab

Date/Time: 3/4/2023 1:30pm

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-28 Cooler, MJHS, Science Wing Hall
Pb EPA 200.8

Matrix: Drinking Water

Type: Grab

Date/Time: 3/4/2023 1:40pm

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-29 Cooler, MJHS, Boys Locker Room
Pb EPA 200.8

Matrix: Drinking Water

Type: Grab

Date/Time: 3/4/2023 1:50pm

A - PI 250ml leak-proof (Nalgene) HNO3

2305494-30 NO sample
JSV 3-6-23
Pb EPA-200.8

Matrix: Drinking Water

Type: Grab

Date/Time: NO Sample

A - PI 250ml leak-proof (Nalgene) HNO3

JSV 3-6-23

Relinquished By

Date/Time

Received By

Date/Time

Relinquished By

Date/Time

Received By

Date/Time

Relinquished By

Date/Time

Received at Laboratory By

Date/Time

The Client, by signing (or having the client's agent sign), agrees to MJRA's Terms and Conditions and to pay for the above requested services including any additional associated fees incurred.

Sample Kit Prepared By <u>JSV</u>	Date/Time <u>2/8/23</u>
Sample Temp (°C): <u>15.8</u>	
Samples on Ice?	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA <input type="checkbox"/>
Approved By: <u>JSV</u>	
Entered By:	

M.J. Reider Associates, Inc.**MJRA Terms & Conditions**

All samples submitted must be accompanied by signed documentation representing a Chain of Custody (COC). The COC Record acts as a contract between the client and MJRA. Signing the COC form gives approval for MJRA to perform the requested analyses and is an agreement to pay for the cost of such analyses. COC Records must be completed in black or blue indelible ink (must not run when wet). COC documentation begins at the time of sample collection. Client is required to document all sample details prior to releasing samples to MJRA. All samples must be placed on ice immediately after sampling and shipped or delivered to the laboratory in a manner that will maintain the sample temperature above freezing and below 6C (loose ice is preferred).

Sample Submission, Sample Acceptance & Sampling Containers

Included on the COC must be the sample description, date and time of collection (including start and stop for composites), container size and type, preservative information, sample matrix, indication of whether the sample is a grab or composite, number of containers & a list of the tests to be performed. Poor sample collection technique, inappropriate sampling containers and/or improper sample preservation may lead to sample rejection. Suitable sample containers, labels, and preservatives (as applicable), along with blank COCs are provided at no additional cost.

Turnaround Times (TAT)

Average TAT for test results range from 5 to 15 working days depending on the specific analyses and time of year submitted. Faster turnaround times (*RUSH TAT) may be available depending on the current workload in a particular department and the nature of the analyses requested. We encourage you to verify requests for expedited sample results with one of our Technical Directors prior to sample submittal. Without confirmation from a Technical Director, your results may not be completed by your deadline. *RUSH TAT Surcharges are applied for expedited turnaround times.

Analytical Results, Sample Collection Integrity & Subcontracting

Analytical values are for the sample as submitted and relate only to the item tested. The value indicates a snapshot of the constituent content of the sample at the time of sample collection. Analytical results can be impacted by poor sample collection technique and/or improper preservation. All sample collection completed by MJRA was performed in accordance with applicable regulatory protocols or as specified in customer specific sampling plans. Constituent content will vary over time based on the matrix of the sample and the physical and chemical changes to its environment. All sample results and laboratory reports are strictly confidential. Results will not be available to anyone except the primary client or authorized party representing the client unless MJRA receives additional permissions from the client. When necessary, MJRA will subcontract certain analyses to a third party accredited laboratory. If client prohibits subcontracting, it must be provided in writing and include instruction on how to proceed with client samples that require third party analyses.


Payment Terms

Payment Terms are Net 30 days. Prices are subject to change without notice. A standing monthly charge of 1.5% of the clients over-30-day-unpaid balance may be added to the balance after 30 days and each month thereafter (day 31, 61, 91 etc.). The laboratory accepts all major credit cards, ACH transactions, checks and cash. New clients must pay for all services rendered prior to sample collection and/or in some cases report processing. Clients must contact the MJRA accounting department to pursue a credit-based account. MJRA reserves the right to terminate the client's credit account and to refuse to perform additional services on a credit basis if any balance is outstanding for more than 60 days.

Warranty & Litigation

MJRA does not guarantee any results of its services but has agreed to use its best efforts, in accordance with the standards and practices of the industry, to cause such results to be accurate and complete. We disclaim any other warranties, expressed or implied, including a warranty of fitness for a particular purpose and warranty of merchantability. Clients agree that they shall reimburse MJRA for any and all fees, cost and litigation expenses, including reasonable attorney fees incurred by MJRA in obtaining payment for the services rendered. All costs associated with compliance with any subpoena for documents, testimony, or any other purpose relating to work performed by MJRA, for a client, shall be paid by that client. MJRA's aggregate liability for negligent acts and omissions and of an intentional breach by MJRA will not exceed the fee paid for the services. Client agrees to indemnify and hold MJRA harmless for any and all liabilities in excess of said amount. Neither MJRA nor the client shall be liable to the other for special, incidental consequential or punitive liability or damages included but not limited to those arising from delay, loss of use, loss of profits or revenues. MJRA will not be liable to the client unless the client has notified MJRA of the discovery of the alleged negligent act, error, omissions or breach within 30 days of the day of its discovery and within one year of the date of invoice.

Reviewed and Approved by:



Paulina Laudan Webb
Technical Director of Microbiology

107 Angelica Street ○ Reading, PA 19611 ○ www.mjreider.com ○ (610) 374-5129 ○ fax (610) 374-7234**This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.**

NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)